



## TEST CERTIFICATE

TC NO: AFPL/2026-27/3656

DATE: 2026-08-11

CLIENT NAME: Alivus Lifescience Ltd - Dahej Plant

CLIENT PO NO: 5400001021

PO DATE: 2026-06-20

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/8630 TO 8639

TESTING DATE: 2026-08-11

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

| MANUFACTURER : AIRFIL FILTECH PVT. LTD.              |                       |                     |                 |
|------------------------------------------------------|-----------------------|---------------------|-----------------|
| TYPE OF FILTER : RISER FILTER - 10 MICRON (BOX TYPE) |                       |                     |                 |
| PRODUCT DETAILS                                      |                       |                     |                 |
| FILTER MEDIA                                         | FILTER CAPACITY       | FILTER DIMENSION    | MOC             |
| HDPE + Non-Woven Synthetic Media + HDPE              | 1040 CFM              | 790 X 490 X 25 MM   | ALUMINIUM       |
| AIR FLOW RATE                                        | INITIAL PRESSURE DROP | FINAL PRESSURE DROP | TEMPERATURE     |
| 1040 CFM                                             | 40 - 50 Pa            | 150 Pa              | AMBIENT         |
| TEST DATA                                            |                       |                     |                 |
| TEST AIRFLOW                                         | AIR VELOCITY          |                     | AIR TEMPERATURE |
| 1040 CFM                                             | 250 FPM               |                     | 25 °C           |
| TEST RESULT                                          |                       |                     |                 |
| INITIAL PRESSURE DROP (Pa)                           | EFFICIENCY            |                     | FILTER CLASS    |
| 40 ± 5 %                                             | 90% DOWN TO 10 MICRON |                     | EU 04           |
| TEST TYPE : BS EN 779                                |                       |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)