



AIR FILTER

TEST CERTIFICATE

TC NO: AFPL/2026-27/3662

DATE: 2026-08-11

CLIENT NAME: Alivus Lifescience Ltd - Dahej Plant

CLIENT PO NO: 5400001021

PO DATE: 2026-06-20

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/8688 TO 8697

TESTING DATE: 2026-08-11

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : RISER FILTER - 10 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + Non-Woven Synthetic Media + HDPE	645 CFM	490 X 490 X 25 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
645 CFM	40 - 50 Pa	150 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
645 CFM	250 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
40 ± 5 %	90% DOWN TO 10 MICRON		EU 04
TEST TYPE : BS EN 779			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in