



## TEST CERTIFICATE

TC NO: AFPL/2026-27/3673

DATE: 2026-08-12

CLIENT NAME: SHREE VISHWAKARMA ALU PROJECTS PVT LTD

CLIENT PO NO: SV-PO-2526-0577

PO DATE: 2026-02-18

FILTER SERIAL NUMBER: AFPL/2025-26/EU03/18836 TO 18845

TESTING DATE: 2026-03-23

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                      |                       |                     |                 |
|------------------------------------------------------|-----------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.              |                       |                     |                 |
| TYPE OF FILTER : RISER FILTER - 20 MICRON (BOX TYPE) |                       |                     |                 |
| PRODUCT DETAILS                                      |                       |                     |                 |
| FILTER MEDIA                                         | FILTER CAPACITY       | FILTER DIMENSION    | MOC             |
| HDPE + Non-Woven Synthetic Media + Alu Mesh          | 845 CFM               | 720 X 435 X 20 MM   | ALUMINIUM       |
| AIR FLOW RATE                                        | INITIAL PRESSURE DROP | FINAL PRESSURE DROP | TEMPERATURE     |
| 845 CFM                                              | 30 - 40 Pa            | 150 PA              | AMBIENT         |
| TEST DATA                                            |                       |                     |                 |
| TEST AIRFLOW                                         | AIR VELOCITY          |                     | AIR TEMPERATURE |
| 845 CFM                                              | 250 FPM               |                     | 25 °C           |
| TEST RESULT                                          |                       |                     |                 |
| INITIAL PRESSURE DROP (Pa)                           | EFFICIENCY            |                     | FILTER CLASS    |
| 30 ± 5 %                                             | 90% DOWN TO 20 MICRON |                     | EU 03           |
| TEST TYPE : BS EN 779                                |                       |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)