



TEST CERTIFICATE

TC NO: AFPL/2026-27/3709

DATE: 2026-08-12

CLIENT NAME: SHREE VISHWAKARMA ALU PROJECTS PVT LTD

CLIENT PO NO: SV-PO-2526-0577

PO DATE: 2026-02-18

FILTER SERIAL NUMBER: AFPL/2025-26/EU03/19180 TO 19189

TESTING DATE: 2026-03-23

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : RISER FILTER - 20 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + Non-Woven Synthetic Media + Alu Mesh	490 CFM	420 X 435 X 20 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
490 CFM	30 - 40 Pa	150 PA	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
490 CFM	250 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
30 ± 5 %	90% DOWN TO 20 MICRON		EU 03
TEST TYPE : BS EN 779			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in