



TEST CERTIFICATE

TC NO: AFPL/2026-27/3761

DATE: 2026-08-12

CLIENT NAME: CHILL AND DRILL (OPC) PVT. LTD.

CLIENT PO NO: PO-4500019002

PO DATE: 26-07-206

FILTER SERIAL NUMBER: AFPL/2026-27/EU13/8389

TESTING DATE: 2026-08-11

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : HEPA FILTER – 0.3 MICRON (FLANGE TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
IMPORTED SUBMICRONIC GLASS FIBRE MEDIA + AL. SEPARATER	2000 CFM	610 X 610 X 300 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
2000 CFM	250 Pa	600 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
2000 CFM	500 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
250 ± 5 %	99.997 % DOWN TO 0.3 MICRON		EU 13
TEST TYPE : BS EN 1822			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in