



## TEST CERTIFICATE

TC NO: AFPL/2026-27/3849

DATE: 2026-08-16

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED

CLIENT PO NO: PO-4700076445

PO DATE: 2026-07-16

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/8910 TO 8919

TESTING DATE: 2026-08-16

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                       |                        |                     |                 |
|-------------------------------------------------------|------------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.               |                        |                     |                 |
| TYPE OF FILTER : PRE FILTER - 10 MICRON (FLANGE TYPE) |                        |                     |                 |
| PRODUCT DETAILS                                       |                        |                     |                 |
| FILTER MEDIA                                          | FILTER CAPACITY        | FILTER DIMENSION    | MOC             |
| HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE               | 500 CFM                | 305 X 305 X 46 MM   | ALUMINIUM       |
| AIR FLOW RATE                                         | INITIAL PRESSURE DROP  | FINAL PRESSURE DROP | TEMPERATURE     |
| 500 CFM                                               | 40 - 50 Pa             | 150 Pa              | AMBIENT         |
| TEST DATA                                             |                        |                     |                 |
| TEST AIRFLOW                                          | AIR VELOCITY           |                     | AIR TEMPERATURE |
| 500 CFM                                               | 500 FPM                |                     | 25 °C           |
| TEST RESULT                                           |                        |                     |                 |
| INITIAL PRESSURE DROP (Pa)                            | EFFICIENCY             |                     | FILTER CLASS    |
| 40 ± 5 %                                              | 90 % DOWN TO 10 MICRON |                     | EU 04           |
| TEST TYPE : BS EN 779                                 |                        |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)