



## TEST CERTIFICATE

TC NO: AFPL/2026-27/3856

DATE: 2026-08-16

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED

CLIENT PO NO: PO-4700076445

PO DATE: 2026-07-16

FILTER SERIAL NUMBER: AFPL/2026-27/EU07/8967 TO 8976

TESTING DATE: 2026-08-16

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                       |                       |                     |             |
|-------------------------------------------------------|-----------------------|---------------------|-------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.               |                       |                     |             |
| TYPE OF FILTER : FINE FILTER - 3 MICRON (FLANGE TYPE) |                       |                     |             |
| PRODUCT DETAILS                                       |                       |                     |             |
| FILTER MEDIA                                          | FILTER CAPACITY       | FILTER DIMENSION    | MOC         |
| HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE               | 2000 CFM              | 610 X 610 X 305 MM  | ALUMINIUM   |
| AIR FLOW RATE                                         | INITIAL PRESSURE DROP | FINAL PRESSURE DROP | TEMPERATURE |
| 2000 CFM                                              | 70 - 80 Pa            | 450 Pa              | AMBIENT     |
| TEST DATA                                             |                       |                     |             |
| TEST AIRFLOW                                          | AIR VELOCITY          | AIR TEMPERATURE     |             |
| 2000 CFM                                              | 500 FPM               | 25 °C               |             |
| TEST RESULT                                           |                       |                     |             |
| INITIAL PRESSURE DROP (Pa)                            | EFFICIENCY            | FILTER CLASS        |             |
| 70 ± 5 %                                              | 99% DOWN TO 03 MICRON | EU 07               |             |
| TEST TYPE : BS EN 779                                 |                       |                     |             |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)