



## TEST CERTIFICATE

TC NO: AFPL/2026-27/3882

DATE: 2026-08-16

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED

CLIENT PO NO: PO-4700070123

PO DATE: 2026-05-19

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/8245 TO 8254

TESTING DATE: 2026-08-16

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                      |                        |                     |                 |
|------------------------------------------------------|------------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.              |                        |                     |                 |
| TYPE OF FILTER : RISER FILTER - 10 MICRON (BOX TYPE) |                        |                     |                 |
| PRODUCT DETAILS                                      |                        |                     |                 |
| FILTER MEDIA                                         | FILTER CAPACITY        | FILTER DIMENSION    | MOC             |
| HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE              | 1593 CFM               | 780 X 380 X 20 MM   | ALUMINIUM       |
| AIR FLOW RATE                                        | INITIAL PRESSURE DROP  | FINAL PRESSURE DROP | TEMPERATURE     |
| 1593 CFM                                             | 40 - 50 Pa             | 150 Pa              | AMBIENT         |
| TEST DATA                                            |                        |                     |                 |
| TEST AIRFLOW                                         | AIR VELOCITY           |                     | AIR TEMPERATURE |
| 1593 CFM                                             | 500 FPM                |                     | 25 °C           |
| TEST RESULT                                          |                        |                     |                 |
| INITIAL PRESSURE DROP (Pa)                           | EFFICIENCY             |                     | FILTER CLASS    |
| 40 ± 5 %                                             | 90 % DOWN TO 10 MICRON |                     | EU 04           |
| TEST TYPE : BS EN 779                                |                        |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)