



TEST CERTIFICATE

TC NO: AFPL/2026-27/3886

DATE: 2026-08-16

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED

CLIENT PO NO: PO-4700070123

PO DATE: 2026-05-19

FILTER SERIAL NUMBER: AFPL/2026-27/EU07/ 8282 & 8289

TESTING DATE: 2026-08-16

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : HIGH TEMP FINE FILTER - 3 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
AL MESH + FIRE RETARDANT MEDIA + AL MESH	2000 CFM	610 X 610 X 300 MM	SS - 304
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
2000 CFM	70 - 80 Pa	450 Pa	150 °C
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
2000 CFM	500 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
70 ± 5 %	90 % DOWN TO 10 MICRON		EU 07
TEST TYPE : BS EN 779			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in