



## TEST CERTIFICATE

TC NO: AFPL/2026-27/4012

DATE: 2026-09-04

CLIENT NAME: HiMedia Laboratories Pvt. Ltd.

CLIENT PO NO: 4500048381

PO DATE: 2026-04-17

FILTER SERIAL NUMBER: AFPL/2026-27/EU09/1124

TESTING DATE: 2026-09-04

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

|                                                                 |                            |                     |                 |
|-----------------------------------------------------------------|----------------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                         |                            |                     |                 |
| TYPE OF FILTER : SEMI HEPA FILTER – 0.3 MICRON (FLANGE TYPE)    |                            |                     |                 |
| PRODUCT DETAILS                                                 |                            |                     |                 |
| FILTER MEDIA                                                    | FILTER CAPACITY            | FILTER DIMENSION    | MOC             |
| IMPORTED SUBMICRONIC GLASS FIBRE MEDIA PLEATED BY HOT MELT GLUE | 2000 CFM                   | 610 X 610 X 305 MM  | ALUMINIUM       |
| AIR FLOW RATE                                                   | INITIAL PRESSURE DROP      | FINAL PRESSURE DROP | TEMPERATURE     |
| 2000 CFM                                                        | 250 Pa                     | 600 Pa              | AMBIENT         |
| TEST DATA                                                       |                            |                     |                 |
| TEST AIRFLOW                                                    | AIR VELOCITY               |                     | AIR TEMPERATURE |
| 2000 CFM                                                        | 250 FPM                    |                     | 25 °C           |
| TEST RESULT                                                     |                            |                     |                 |
| INITIAL PRESSURE DROP (Pa)                                      | EFFICIENCY                 |                     | FILTER CLASS    |
| 250 ± 5 %                                                       | 50-85 % Down To 0.3 Micron |                     | EU 09           |
| TEST TYPE : BS EN 779                                           |                            |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)