



## TEST CERTIFICATE

TC NO: AFPL/2026-27/4037

DATE: 2026-09-06

CLIENT NAME: BALAJI REFRIGERATION SERVICE

CLIENT PO NO: PO/BRS/2026-27/709

PO DATE: 07.07.2026

FILTER SERIAL NUMBER: AFPL/2026-27/EU05/9644 TO 9653

TESTING DATE: 2026-07-04

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                       |                       |                     |                 |
|-------------------------------------------------------|-----------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.               |                       |                     |                 |
| TYPE OF FILTER : FINE FILTER - 5 MICRON (FLANGE TYPE) |                       |                     |                 |
| PRODUCT DETAILS                                       |                       |                     |                 |
| FILTER MEDIA                                          | FILTER CAPACITY       | FILTER DIMENSION    | MOC             |
| HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE (Rod Support) | 2000 CFM              | 610 X 610 X 150 MM  | ALUMINIUM       |
| AIR FLOW RATE                                         | INITIAL PRESSURE DROP | FINAL PRESSURE DROP | TEMPERATURE     |
| 2000 CFM                                              | 60 - 70 Pa            | 450 Pa              | AMBIENT         |
| TEST DATA                                             |                       |                     |                 |
| TEST AIRFLOW                                          | AIR VELOCITY          |                     | AIR TEMPERATURE |
| 2000 CFM                                              | 500 FPM               |                     | 25 °C           |
| TEST RESULT                                           |                       |                     |                 |
| INITIAL PRESSURE DROP (Pa)                            | EFFICIENCY            |                     | FILTER CLASS    |
| 60 ± 5 %                                              | 95% DOWN TO 05 MICRON |                     | EU 05           |
| TEST TYPE : BS EN 779                                 |                       |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)