



TEST CERTIFICATE

TC NO: AFPL/2026-27/4043

DATE: 2026-09-06

CLIENT NAME: BALAJI REFRIGERATION SERVICE

CLIENT PO NO: PO/BRS/2026-27/709

PO DATE: 07.07.2026

FILTER SERIAL NUMBER: AFPL/2026-27/EU05/9704 TO 9713

TESTING DATE: 2026-07-04

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : FINE FILTER - 5 MICRON (FLANGE TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE (Rod Support)	2000 CFM	610 X 610 X 150 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
2000 CFM	60 - 70 Pa	450 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
2000 CFM	500 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
60 ± 5 %	95% DOWN TO 05 MICRON		EU 05
TEST TYPE : BS EN 779			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in