



## TEST CERTIFICATE

TC NO: AFPL/2026-27/4130

DATE: 2026-09-10

CLIENT NAME: MAKCUR LABORATORIES LTD

CLIENT PO NO: MAK/NEW GEN/012

PO DATE: 2026-08-19

FILTER SERIAL NUMBER: AFPL/2026-27/EU13/1483

TESTING DATE: 2026-08-19

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

|                                                         |                             |                     |                 |
|---------------------------------------------------------|-----------------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                 |                             |                     |                 |
| TYPE OF FILTER : HEPA FILTER – 0.3 MICRON (FLANGE TYPE) |                             |                     |                 |
| PRODUCT DETAILS                                         |                             |                     |                 |
| FILTER MEDIA                                            | FILTER CAPACITY             | FILTER DIMENSION    | MOC             |
| IMPORTED SUBMICRONIC GLASS FIBRE MEDIA + AL. SEPARATER  | 1500 CFM                    | 460 X 610 X 292 MM  | ALUMINIUM       |
| AIR FLOW RATE                                           | INITIAL PRESSURE DROP       | FINAL PRESSURE DROP | TEMPERATURE     |
| 1500 CFM                                                | 250 Pa                      | 600 Pa              | AMBIENT         |
| TEST DATA                                               |                             |                     |                 |
| TEST AIRFLOW                                            | AIR VELOCITY                |                     | AIR TEMPERATURE |
| 1500 CFM                                                | 500 FPM                     |                     | 25 °C           |
| TEST RESULT                                             |                             |                     |                 |
| INITIAL PRESSURE DROP (Pa)                              | EFFICIENCY                  |                     | FILTER CLASS    |
| 250 ± 5 %                                               | 99.997 % DOWN TO 0.3 MICRON |                     | EU 13           |
| TEST TYPE : BS EN 1822                                  |                             |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)