



## TEST CERTIFICATE

TC NO: AFPL/2026-27/4137

DATE: 2026-09-10

CLIENT NAME: MAKCUR LABORATORIES LTD

CLIENT PO NO: MAK/CEPHA BLOCK/021

PO DATE: 2026-08-25

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/1253

TESTING DATE: 2026-09-09

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                    |                        |                     |                 |
|----------------------------------------------------|------------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.            |                        |                     |                 |
| TYPE OF FILTER : PRE FILTER - 10 MICRON (BOX TYPE) |                        |                     |                 |
| PRODUCT DETAILS                                    |                        |                     |                 |
| FILTER MEDIA                                       | FILTER CAPACITY        | FILTER DIMENSION    | MOC             |
| HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE            | 980 CFM                | 298 X 610 X 50 MM   | ALUMINIUM       |
| AIR FLOW RATE                                      | INITIAL PRESSURE DROP  | FINAL PRESSURE DROP | TEMPERATURE     |
| 980 CFM                                            | 40 - 50 Pa             | 150 Pa              | AMBIENT         |
| TEST DATA                                          |                        |                     |                 |
| TEST AIRFLOW                                       | AIR VELOCITY           |                     | AIR TEMPERATURE |
| 980 CFM                                            | 500 FPM                |                     | 25 °C           |
| TEST RESULT                                        |                        |                     |                 |
| INITIAL PRESSURE DROP (Pa)                         | EFFICIENCY             |                     | FILTER CLASS    |
| 40 ± 5 %                                           | 90 % DOWN TO 10 MICRON |                     | EU 04           |
| TEST TYPE : BS EN 779                              |                        |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)