



TEST CERTIFICATE

TC NO: AFPL/2026-27/4141

DATE: 2026-09-16

CLIENT NAME: APEX MEP Projects

CLIENT PO NO: APEX MEP Projects, Ahmedabad

PO DATE: 2026-09-08

FILTER SERIAL NUMBER: AFPL/202526/H14/10575

TESTING DATE: 2026-09-15

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : MINIPLEAT HEPA FILTER – 0.3 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
IMPORTED SUBMICRONIC GLASS FIBRE MEDIA PLEATED BY HOT MELT GLUE	1000 CFM	1220 X 610 X 70 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
1000 CFM	250 Pa	600 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
1000 CFM	125 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
250 ± 5 %	99.997 % DOWN TO 0.3 MICRON		H 14
TEST TYPE : BS EN 1822			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in