



## TEST CERTIFICATE

TC NO: AFPL/2026-27/4156

DATE: 2026-09-20

CLIENT NAME: CLIMATE GRIP PVT. LTD

CLIENT PO NO: PO-63

PO DATE: 2026-08-10

FILTER SERIAL NUMBER: AFPL/2026-27/EU05/10703 TO 10705

TESTING DATE: 2026-09-18

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                             |                       |                     |                 |
|-------------------------------------------------------------|-----------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                     |                       |                     |                 |
| TYPE OF FILTER : FINE FILTER - 5 MICRON (FLANGE TYPE)       |                       |                     |                 |
| PRODUCT DETAILS                                             |                       |                     |                 |
| FILTER MEDIA                                                | FILTER CAPACITY       | FILTER DIMENSION    | MOC             |
| HDPE + Non-Woven Synthetic Media + HDPE Supported By Al Rod | 1000 CFM              | 610 X 305 X 300 MM  | ALUMINIUM       |
| AIR FLOW RATE                                               | INITIAL PRESSURE DROP | FINAL PRESSURE DROP | TEMPERATURE     |
| 1000 CFM                                                    | 70 - 80 Pa            | 450 Pa              | AMBIENT         |
| TEST DATA                                                   |                       |                     |                 |
| TEST AIRFLOW                                                | AIR VELOCITY          |                     | AIR TEMPERATURE |
| 1000 CFM                                                    | 500 FPM               |                     | 25 °C           |
| TEST RESULT                                                 |                       |                     |                 |
| INITIAL PRESSURE DROP (Pa)                                  | EFFICIENCY            |                     | FILTER CLASS    |
| 70 ± 5 %                                                    | 95% DOWN TO 05 MICRON |                     | EU 05           |
| TEST TYPE : BS EN 779                                       |                       |                     |                 |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)