



TEST CERTIFICATE

TC NO: AFPL/2026-27/4183

DATE: 2026-09-21

CLIENT NAME: APEX AIRTECH SYSTEMS

CLIENT PO NO: PO-AAS/299/26-27

PO DATE: 2026-09-06

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/10810 TP 10815

TESTING DATE: 2026-09-20

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : PRE FILTER - 10 MICRON (FLANGE TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE	335 CFM	250 X 250 X 50 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
335 CFM	40 - 50 Pa	150 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
335 CFM	500 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
40 ± 5 %	90 % DOWN TO 10 MICRON		EU 04
TEST TYPE : BS EN 779			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in