



AIR FILTER

TEST CERTIFICATE

TC NO: AFPL/2026-27/4229

DATE: 2026-09-28

CLIENT NAME: Ryzer Pharmaceutical Pvt Ltd, Mansa

CLIENT PO NO: POOM260108

PO DATE: 2026-09-17

FILTER SERIAL NUMBER: AFPL/202627/EU03/11528 to 11538

TESTING DATE: 2026-09-27

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : RISER FILTER - 20 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + Non-Woven Synthetic Media + HDPE Mesh (Rod Supported)	445 CFM	585 X 285 X 25 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
445 CFM	30 - 40 Pa	150 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
445 CFM	250 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
30 ± 5 %	85 % DOWN TO 20 MICRON		EU 03
TEST TYPE : BS EN 779			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in