



# AIR FILTER

## TEST CERTIFICATE

TC NO: AFPL/2026-27/4234

DATE: 2026-09-28

CLIENT NAME: Ryzer Pharmaceutical Pvt Ltd, Mansa

CLIENT PO NO: POOM260108

PO DATE: 2026-09-17

FILTER SERIAL NUMBER: AFPL/202627/EU04/11565

TESTING DATE: 2026-09-27

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                             |                        |                     |                 |
|-------------------------------------------------------------|------------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                     |                        |                     |                 |
| TYPE OF FILTER : PRE FILTER - 10 MICRON (FLANGE TYPE)       |                        |                     |                 |
| PRODUCT DETAILS                                             |                        |                     |                 |
| FILTER MEDIA                                                | FILTER CAPACITY        | FILTER DIMENSION    | MOC             |
| HDPE + Non-Woven Synthetic Media + HDPE Mesh (Pleated Type) | 500 CFM                | 305 X 305 X 50 MM   | ALUMINIUM       |
| AIR FLOW RATE                                               | INITIAL PRESSURE DROP  | FINAL PRESSURE DROP | TEMPERATURE     |
| 500 CFM                                                     | 40 - 50 Pa             | 150 Pa              | AMBIENT         |
| TEST DATA                                                   |                        |                     |                 |
| TEST AIRFLOW                                                | AIR VELOCITY           |                     | AIR TEMPERATURE |
| 500 CFM                                                     | 500 FPM                |                     | 25 °C           |
| TEST RESULT                                                 |                        |                     |                 |
| INITIAL PRESSURE DROP (Pa)                                  | EFFICIENCY             |                     | FILTER CLASS    |
| 30 ± 5 %                                                    | 90 % DOWN TO 10 MICRON |                     | EU 04           |
| TEST TYPE : BS EN 779                                       |                        |                     |                 |

INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)