



## TEST CERTIFICATE

TC NO: AFPL/2026-27/4253

DATE: 2026-09-29

CLIENT NAME: HiMedia Laboratories Pvt. Ltd

CLIENT PO NO: 4500048581

PO DATE: 2026-09-02

FILTER SERIAL NUMBER: AFPL/202627/EU04/11079 TO 11088

TESTING DATE: 2026-09-28

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                    |                          |                        |                    |
|----------------------------------------------------|--------------------------|------------------------|--------------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.            |                          |                        |                    |
| TYPE OF FILTER : PRE FILTER - 10 MICRON (BOX TYPE) |                          |                        |                    |
| PRODUCT DETAILS                                    |                          |                        |                    |
| FILTER MEDIA                                       | FILTER CAPACITY          | FILTER DIMENSION       | MOC                |
| HDPE + Non-Woven Synthetic Media<br>+ HDPE Mesh    | 415 CFM                  | 535 X 290 X 25MM       | ALUMINIUM          |
| AIR FLOW RATE                                      | INITIAL PRESSURE<br>DROP | FINAL PRESSURE<br>DROP | TEMPERATURE        |
| 415 CFM                                            | 40 - 50 Pa               | 150 Pa                 | AMBIENT            |
| TEST DATA                                          |                          |                        |                    |
| TEST AIRFLOW                                       | AIR VELOCITY             |                        | AIR<br>TEMPERATURE |
| 415 CFM                                            | 250 FPM                  |                        | 25 °C              |
| TEST RESULT                                        |                          |                        |                    |
| INITIAL PRESSURE DROP (Pa)                         | EFFICIENCY               |                        | FILTER CLASS       |
| 40 ± 5 %                                           | 90 % DOWN TO 10 MICRON   |                        | EU 04              |
| TEST TYPE : BS EN 779                              |                          |                        |                    |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)