



TEST CERTIFICATE

TC NO: AFPL/2026-27/4271

DATE: 2026-09-29

CLIENT NAME: ORCHID SCIENTIFIC & INNOVATIVE INDIA PVT LTD.

CLIENT PO NO: OSIPL/26-27/PO/893

PO DATE: 2026-09-22

FILTER SERIAL NUMBER: AFPL/202627/EU04/11602 & 11603

TESTING DATE: 2026-09-28

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : PRE FILTER - 10 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE	80 CFM	200 X 150 X 20 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
80 CFM	40 - 50 Pa	150 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
80 CFM	250 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
40 ± 5 %	90 % DOWN TO 10 MICRON		EU 04
TEST TYPE : BS EN 779			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in