



TEST CERTIFICATE

TC NO: AFPL/2026-27/4282

DATE: 2026-09-30

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED - PALGHAR PLANT

CLIENT PO NO: PO-4500020105

PO DATE: 2026-08-18

FILTER SERIAL NUMBER: AFPL/202627/EU04/11664 & 11665

TESTING DATE: 2026-09-28

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : PRE FILTER - 20 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + Non-Woven Synthetic Media + HDPE Supported By Al Rod	301 CFM	330 X 340 X 25MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
301 CFM	20 - 30 Pa	150 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
301 CFM	250 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
20 ± 5 %	85% DOWN TO 20 MICRON		EU 04
TEST TYPE : BS EN 779			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in