



TEST CERTIFICATE

TC NO: AFPL/2026-27/4326

DATE: 2026-10-03

CLIENT NAME: JYOTI CAPSULATION PVT LTD

CLIENT PO NO: JCPL/26-27/128

PO DATE: 2026-09-29

FILTER SERIAL NUMBER: AFPL/2026-27/EU13/11861

TESTING DATE: 2026-10-01

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : HEPA FILTER – 0.3 MICRON (FLANGE TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
IMPORTED SUBMICRONIC GLASS FIBRE MEDIA + AL. SEPARATER	694 CFM	508 X 508 X 300 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
694 CFM	250 Pa	600 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
694 CFM	250 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
250 ± 5 %	99.97 % DOWN TO 0.3 MICRON		EU 13
TEST TYPE : BS EN 1822			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in