

TEST CERTIFICATE

TC NO:

CLIENT NAME:

CLIENT PO NO: 12345

FILTER SERIAL NUMBER: SER/001

EQUIPMENT USED FOR TESTING VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

DATE:

PO DATE: 2026-07-14

TESTING DATE: 2026-07-14

MANUFACTURER: - AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER: FINE FILTER -- 3 MICRON (FLANGE TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE	2000 CFM	610 X 610 X 305 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
2000 CFM	70 - 80 Pa	450 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY	AIR TEMPERATURE	
2000 CFM ± 5%	500 FPM	25 °C	
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY	FILTER CLASS	
70 ± 5 %	99% DOWN TO 3 MICRON	EU 07	
TEST TYPE: BS EN 779			
For Queries Related To TC Please Contact – quality@airfil.in		INSPECTED BY Signature	
		Authorised Signatory	
QR Code		Barcode	