


TEST CERTIFICATE

TC NO:**DATE:****CLIENT NAME:****CLIENT PO NO:** 12345**PO DATE:** 2026-07-14**FILTER SERIAL NUMBER:** SER/001**TESTING DATE:** 2026-07-14**EQUIPMENT USED FOR TESTING** VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

MANUFACTURER: - AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER: FINE FILTER -- 3 MICRON (FLANGE TYPE)			
<u>PRODUCT DETAILS</u>			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE	2000 CFM	610 X 610 X 305 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
2000 CFM	70 - 80 Pa	450 Pa	AMBIENT
<u>TEST DATA</u>			
TEST AIRFLOW	AIR VELOCITY	AIR TEMPERATURE	
2000 CFM $\pm$ 5%	500 FPM	25 °C	
<u>TEST RESULT</u>			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY	FILTER CLASS	
70 $\pm$ 5 %	99% DOWN TO 3 MICRON	EU 07	
TEST TYPE: BS EN 779			
For Queries Related To TC Please Contact – quality@airfil.in		INSPECTED BY Signature	
		Authorised Signatory	
		 AFPL/2026-27/100	