



TEST CERTIFICATE

TC NO: AFPL/2026-27/3458971

DATE: 2026-07-22

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED

CLIENT PO NO: PO-4500019002

PO DATE: 2026-07-04

FILTER SERIAL NUMBER: 484515

TESTING DATE: 2026-07-21

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : PRE FILTER - 10 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE	691 CFM	585 X440 X 15 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
691 CFM	40 - 50 Pa	150 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
691 CFM	250 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
40 ± 5 %	99% DOWN TO 10 MICRON		EU 04
TEST TYPE : BS EN 779 INSPECTED BY			

INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in

AIRFIL FILTECH PVT. LTD.

Email : sales@airfil.in | Website : www.airfil.in