



# AIR FILTER

## TEST CERTIFICATE

TC NO: AFPL/2026-27/4289

DATE: 2026-09-30

CLIENT NAME: FABLAB

CLIENT PO NO: FLB/HVAC/26-27/D-03

PO DATE: 2026-09-25

FILTER SERIAL NUMBER: AFPL/2026-27/H14/11686

TESTING DATE: 2026-09-29

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

|                                                                          |                                  |                     |                 |
|--------------------------------------------------------------------------|----------------------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                                  |                                  |                     |                 |
| TYPE OF FILTER : GEAL SEAL MINIPLEAT HEPA FILTER – 0.3 MICRON (BOX TYPE) |                                  |                     |                 |
| PRODUCT DETAILS                                                          |                                  |                     |                 |
| FILTER MEDIA                                                             | FILTER CAPACITY                  | FILTER DIMENSION    | MOC             |
| IMPORTED<br>SUBMICRONIC GLASS<br>FIBRE MEDIA PLEATED<br>BY HOT MELT GLUE | 1000 CFM                         | 610 X 610 X 105 MM  | ALUMINIUM       |
| AIR FLOW RATE                                                            | INITIAL PRESSURE DROP            | FINAL PRESSURE DROP | TEMPERATURE     |
| 1000 CFM                                                                 | 250 Pa                           | 600 Pa              | AMBIENT         |
| TEST DATA                                                                |                                  |                     |                 |
| TEST AIRFLOW                                                             | AIR VELOCITY                     |                     | AIR TEMPERATURE |
| 1000 CFM                                                                 | 250 FPM                          |                     | 25 °C           |
| TEST RESULT                                                              |                                  |                     |                 |
| INITIAL PRESSURE DROP<br>(Pa)                                            | EFFICIENCY                       |                     | FILTER CLASS    |
| 250 ± 5 %                                                                | 99.997 % DOWN TO 0.3 MICRON H 14 |                     | -               |
| TEST TYPE : BS EN 1822                                                   |                                  |                     |                 |

|                                                                                                     |                                                                                                               |
|-----------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------|
|                  | INSPECTED BY                                                                                                  |
|                                                                                                     | <br>Authorised Signatory |
| For Queries Related To TC Please Contact : <a href="mailto:quality@airfil.in">quality@airfil.in</a> |                                                                                                               |

AIRFIL FILTECH PVT. LTD.

Email : [sales@airfil.in](mailto:sales@airfil.in) | Website : [www.airfil.in](http://www.airfil.in)