



AIR FILTER

TEST CERTIFICATE

TC NO: AFPL/2026-27/4294

DATE: 2026-09-30

CLIENT NAME: FABLAB

CLIENT PO NO: FLB/HVAC/26-27/D-03

PO DATE: 2026-09-25

FILTER SERIAL NUMBER: AFPL/2026-27/H14/11691

TESTING DATE: 2026-09-29

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : GEAL SEAL MINIPLEAT HEPA FILTER – 0.3 MICRON (BOX TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
IMPORTED SUBMICRONIC GLASS FIBRE MEDIA PLEATED BY HOT MELT GLUE	545 CFM	450 X 450 X 105 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
545 CFM	250 Pa	600 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
545 CFM	250 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
250 ± 5 %	99.997 % DOWN TO 0.3 MICRON H 14		-
TEST TYPE : BS EN 1822			

	INSPECTED BY
	 Authorised Signatory
For Queries Related To TC Please Contact : quality@airfil.in	

AIRFIL FILTECH PVT. LTD.

Email : sales@airfil.in | Website : www.airfil.in