



TEST CERTIFICATE

TC NO: AFPL/2026-27/4299

DATE: 2026-10-01

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED

CLIENT PO NO: PO-4700081468

PO DATE: 2026-08-31

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/11696 TO 11699

TESTING DATE: 2026-10-01

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : HIGH TEMPERATURE PRE FILTER - 10 MICRON (FLANGE TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
Fire Retardent Media + Tissue + HDPE Mesh Both Side (Alu Rod Support)	1398 CFM	510 X 510 X 150 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
-	-	-	-
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
1398 CFM	500 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
40 ± 5 %	90 % DOWN TO 10 MICRON		EU 04
TEST TYPE : BS EN 779			

	INSPECTED BY
	 Authorised Signatory
For Queries Related To TC Please Contact : quality@airfil.in	

AIRFIL FILTECH PVT. LTD.

Email : sales@airfil.in | Website : www.airfil.in