



## TEST CERTIFICATE

TC NO: AFPL/2026-27/4340

DATE: 2026-10-03

CLIENT NAME: JYOTI CAPSULATION PVT LTD

CLIENT PO NO: JCPL/26-27/128

PO DATE: 2026-09-29

FILTER SERIAL NUMBER: AFPL/2026-27/EU13/11875

TESTING DATE: 2026-10-01

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER AND AEROSOL PHOTOMETER

|                                                                 |                             |                     |                 |
|-----------------------------------------------------------------|-----------------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                         |                             |                     |                 |
| TYPE OF FILTER : HEPA FILTER – 0.3 MICRON (FLANGE TYPE)         |                             |                     |                 |
| PRODUCT DETAILS                                                 |                             |                     |                 |
| FILTER MEDIA                                                    | FILTER CAPACITY             | FILTER DIMENSION    | MOC             |
| IMPORTED<br>SUBMICRONIC GLASS<br>FIBRE MEDIA + AL.<br>SEPARATER | 694 CFM                     | 508 X 508 X 300 MM  | ALUMINIUM       |
| AIR FLOW RATE                                                   | INITIAL PRESSURE DROP       | FINAL PRESSURE DROP | TEMPERATURE     |
| 694 CFM                                                         | 250 Pa                      | 600 Pa              | AMBIENT         |
| TEST DATA                                                       |                             |                     |                 |
| TEST AIRFLOW                                                    | AIR VELOCITY                |                     | AIR TEMPERATURE |
| 694 CFM                                                         | 250 FPM                     |                     | 25 °C           |
| TEST RESULT                                                     |                             |                     |                 |
| INITIAL PRESSURE DROP<br>(Pa)                                   | EFFICIENCY                  |                     | FILTER CLASS    |
| 250 ± 5 %                                                       | 99.997 % DOWN TO 0.3 MICRON |                     | EU 13           |
| TEST TYPE : BS EN 1822                                          |                             |                     |                 |

|                                                                                                     |                                                                                                               |
|-----------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------|
|                  | INSPECTED BY                                                                                                  |
|                                                                                                     | <br>Authorised Signatory |
| For Queries Related To TC Please Contact : <a href="mailto:quality@airfil.in">quality@airfil.in</a> |                                                                                                               |

AIRFIL FILTECH PVT. LTD.

Email : [sales@airfil.in](mailto:sales@airfil.in) | Website : [www.airfil.in](http://www.airfil.in)