



# AIR FILTER

## TEST CERTIFICATE

TC NO: AFPL/2026-27/4377

DATE: 2026-10-06

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED - SARIGAM PLANT

CLIENT PO NO: 4500020209

PO DATE: 2026-08-21

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/11700 to 11705

TESTING DATE: 2026-10-04

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                                                                     |                        |                                                                                       |             |
|-----------------------------------------------------------------------------------------------------|------------------------|---------------------------------------------------------------------------------------|-------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                                                             |                        |                                                                                       |             |
| TYPE OF FILTER : PRE FILTER - 10 MICRON (FLANGE TYPE)                                               |                        |                                                                                       |             |
| PRODUCT DETAILS                                                                                     |                        |                                                                                       |             |
| FILTER MEDIA                                                                                        | FILTER CAPACITY        | FILTER DIMENSION                                                                      | MOC         |
| HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE                                                             | 250 CFM                | 305 X 305 X 150 MM                                                                    | ALUMINIUM   |
| AIR FLOW RATE                                                                                       | INITIAL PRESSURE DROP  | FINAL PRESSURE DROP                                                                   | TEMPERATURE |
| 250 CFM                                                                                             | 40 - 50 Pa             | 150 Pa                                                                                | AMBIENT     |
| TEST DATA                                                                                           |                        |                                                                                       |             |
| TEST AIRFLOW                                                                                        | AIR VELOCITY           | AIR TEMPERATURE                                                                       |             |
| 250 CFM                                                                                             | 250 FPM                | 25 °C                                                                                 |             |
| TEST RESULT                                                                                         |                        |                                                                                       |             |
| INITIAL PRESSURE DROP (Pa)                                                                          | EFFICIENCY             | FILTER CLASS                                                                          |             |
| 40 ± 5 %                                                                                            | 90 % DOWN TO 10 MICRON | EU 04                                                                                 |             |
| TEST TYPE : BS EN 779                                                                               |                        | INSPECTED BY                                                                          |             |
|                  |                        |  |             |
|                                                                                                     |                        | Authorised Signatory                                                                  |             |
| For Queries Related To TC Please Contact : <a href="mailto:quality@airfil.in">quality@airfil.in</a> |                        |                                                                                       |             |