



AIR FILTER

TEST CERTIFICATE

TC NO: AFPL/2026-27/4382

DATE: 2026-10-06

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED - SARIGAM PLANT

CLIENT PO NO: 4500020209

PO DATE: 2026-08-21

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/11738

TESTING DATE: 2026-10-04

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : PRE FILTER - 10 MICRON (FLANGE TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE	1491 CFM	610 X 455 X 150 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
1491 CFM	40 - 50 Pa	150 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY	AIR TEMPERATURE	
1491 CFM	250 FPM	25 °C	
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY	FILTER CLASS	
40 ± 5 %	90 % DOWN TO 10 MICRON	EU 04	
TEST TYPE : BS EN 779			
		INSPECTED BY	
		 Authorised Signatory	
For Queries Related To TC Please Contact : quality@airfil.in			