



TEST CERTIFICATE

TC NO: AFPL/2026-27/4390

DATE: 2026-10-06

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED - SARIGAM PLANT

CLIENT PO NO: 4500020209

PO DATE: 2026-08-21

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/11754

TESTING DATE: 2026-10-04

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : HIGH TEMP PRE FILTER - 10 MICRON (FLANGE TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE	1101 CFM	432 X 432 X 150 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
1101 CFM	40 - 50 Pa	150 Pa	150 °C
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
1101 CFM	500 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
40 ± 5 %	90 % DOWN TO 10 MICRON		EU 04
TEST TYPE : BS EN 779			

	INSPECTED BY
	 Authorised Signatory
For Queries Related To TC Please Contact : quality@airfil.in	

AIRFIL FILTECH PVT. LTD.

Email : sales@airfil.in | Website : www.airfil.in