



TEST CERTIFICATE

TC NO: AFPL/2026-27/4396

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED - SARIGAM PLANT

CLIENT PO NO: 4500020209

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/11800

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

DATE: 2026-10-06

PO DATE: 2026-08-21

TESTING DATE: 2026-10-04

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : PRE FILTER - 10 MICRON (FLANGE TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE	561 CFM	457 X 457 X 150 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
561 CFM	40 - 50 Pa	150 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
561 CFM	250 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
40 ± 5 %	90 % DOWN TO 10 MICRON		EU 04
TEST TYPE : BS EN 779			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in