



TEST CERTIFICATE

TC NO: AFPL/2026-27/4400

DATE: 2026-10-06

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED - SARIGAM PLANT

CLIENT PO NO: 4500020209

PO DATE: 2026-08-21

FILTER SERIAL NUMBER: AFPL/2026-27/EU07/11785 TO 11787

TESTING DATE: 2026-10-04

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : FINE FILTER - 3 MICRON (FLANGE TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + Non-Woven Synthetic Media + HDPE Supported By Al Rod	2000 CFM	610 X 610 X 305 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
2000 CFM	70 - 80 Pa	450 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY		AIR TEMPERATURE
2000 CFM	500 FPM		25 °C
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY		FILTER CLASS
70 ± 5 %	99% DOWN TO 03 MICRON		EU 07
TEST TYPE : BS EN 779			

INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in

AIRFIL FILTECH PVT. LTD.

Email : sales@airfil.in | Website : www.airfil.in