



## TEST CERTIFICATE

TC NO: AFPL/2026-27/4401

DATE: 2026-10-06

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED - SARIGAM PLANT

CLIENT PO NO: 4500020209

PO DATE: 2026-08-21

FILTER SERIAL NUMBER: AFPL/2026-27/EU07/11799

TESTING DATE: 2026-10-04

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                             |                       |                     |                 |
|-------------------------------------------------------------|-----------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                     |                       |                     |                 |
| TYPE OF FILTER : FINE FILTER - 3 MICRON (FLANGE TYPE)       |                       |                     |                 |
| PRODUCT DETAILS                                             |                       |                     |                 |
| FILTER MEDIA                                                | FILTER CAPACITY       | FILTER DIMENSION    | MOC             |
| HDPE + Non-Woven Synthetic Media + HDPE Supported By Al Rod | 500 CFM               | 305 X 305 X 300 MM  | ALUMINIUM       |
| AIR FLOW RATE                                               | INITIAL PRESSURE DROP | FINAL PRESSURE DROP | TEMPERATURE     |
| 500 CFM                                                     | 70 - 80 Pa            | 450 Pa              | AMBIENT         |
| TEST DATA                                                   |                       |                     |                 |
| TEST AIRFLOW                                                | AIR VELOCITY          |                     | AIR TEMPERATURE |
| 500 CFM                                                     | 500 FPM               |                     | 25 °C           |
| TEST RESULT                                                 |                       |                     |                 |
| INITIAL PRESSURE DROP (Pa)                                  | EFFICIENCY            |                     | FILTER CLASS    |
| 70 ± 5 %                                                    | 99% DOWN TO 03 MICRON |                     | EU 07           |
| TEST TYPE : BS EN 779                                       |                       |                     |                 |

|                                                                                                     |                                                                                                               |
|-----------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------|
|                  | INSPECTED BY                                                                                                  |
|                                                                                                     | <br>Authorised Signatory |
| For Queries Related To TC Please Contact : <a href="mailto:quality@airfil.in">quality@airfil.in</a> |                                                                                                               |

AIRFIL FILTECH PVT. LTD.

Email : [sales@airfil.in](mailto:sales@airfil.in) | Website : [www.airfil.in](http://www.airfil.in)