



TEST CERTIFICATE

TC NO: AFPL/2026-27/4405

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED - SARIGAM PLANT

CLIENT PO NO: 4500019259

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/11810

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

DATE: 2026-10-06

PO DATE: 2026-07-15

TESTING DATE: 2026-10-04

|                                                       |                        |                     |             |
|-------------------------------------------------------|------------------------|---------------------|-------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.               |                        |                     |             |
| TYPE OF FILTER : PRE FILTER - 10 MICRON (FLANGE TYPE) |                        |                     |             |
| PRODUCT DETAILS                                       |                        |                     |             |
| FILTER MEDIA                                          | FILTER CAPACITY        | FILTER DIMENSION    | MOC         |
| HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE               | 2000 CFM               | 610 X 610 X 50 MM   | ALUMINIUM   |
| AIR FLOW RATE                                         | INITIAL PRESSURE DROP  | FINAL PRESSURE DROP | TEMPERATURE |
| 2000 CFM                                              | 40 - 50 Pa             | 150 Pa              | AMBIENT     |
| TEST DATA                                             |                        |                     |             |
| TEST AIRFLOW                                          | AIR VELOCITY           | AIR TEMPERATURE     |             |
| 2000 CFM                                              | 500 FPM                | 25 °C               |             |
| TEST RESULT                                           |                        |                     |             |
| INITIAL PRESSURE DROP (Pa)                            | EFFICIENCY             | FILTER CLASS        |             |
| 40 ± 5 %                                              | 90 % DOWN TO 10 MICRON | EU 04               |             |
| TEST TYPE : BS EN 779                                 |                        |                     |             |



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)