



## TEST CERTIFICATE

TC NO: AFPL/2026-27/4411

DATE: 2026-10-06

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED - SARIGAM PLANT

CLIENT PO NO: 4500019259

PO DATE: 2026-07-15

FILTER SERIAL NUMBER: AFPL/2026-27/EU04/11905

TESTING DATE: 2026-10-04

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

|                                                                 |                        |                     |                 |
|-----------------------------------------------------------------|------------------------|---------------------|-----------------|
| MANUFACTURER : AIRFIL FILTECH PVT. LTD.                         |                        |                     |                 |
| TYPE OF FILTER : HIGH TEMP PRE FILTER - 10 MICRON (FLANGE TYPE) |                        |                     |                 |
| PRODUCT DETAILS                                                 |                        |                     |                 |
| FILTER MEDIA                                                    | FILTER CAPACITY        | FILTER DIMENSION    | MOC             |
| HDPE + NON-WOVEN SYNTHETIC MEDIA + HDPE                         | 500 CFM                | 305 X 305 X 150 MM  | ALUMINIUM       |
| AIR FLOW RATE                                                   | INITIAL PRESSURE DROP  | FINAL PRESSURE DROP | TEMPERATURE     |
| 500 CFM                                                         | 40 - 50 Pa             | 150 Pa              | 150 °C          |
| TEST DATA                                                       |                        |                     |                 |
| TEST AIRFLOW                                                    | AIR VELOCITY           |                     | AIR TEMPERATURE |
| 500 CFM                                                         | 500 FPM                |                     | 25 °C           |
| TEST RESULT                                                     |                        |                     |                 |
| INITIAL PRESSURE DROP (Pa)                                      | EFFICIENCY             |                     | FILTER CLASS    |
| 40 ± 5 %                                                        | 90 % DOWN TO 10 MICRON |                     | EU 04           |
| TEST TYPE : BS EN 779                                           |                        |                     |                 |

INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : [quality@airfil.in](mailto:quality@airfil.in)

AIRFIL FILTECH PVT. LTD.

Email : [sales@airfil.in](mailto:sales@airfil.in) | Website : [www.airfil.in](http://www.airfil.in)