



TEST CERTIFICATE

TC NO: AFPL/2026-27/4414

CLIENT NAME: MACLEODS PHARMACEUTICALS LIMITED - SARIGAM PLANT

CLIENT PO NO: 4500019259

FILTER SERIAL NUMBER: AFPL/2026-27/EU07/11819 & 11820

EQUIPMENT USED FOR TESTING: VANE TYPE ANEMOMETER

DATE: 2026-10-06

PO DATE: 2026-07-15

TESTING DATE: 2026-10-04

MANUFACTURER : AIRFIL FILTECH PVT. LTD.			
TYPE OF FILTER : FINE FILTER - 3 MICRON (FLANGE TYPE)			
PRODUCT DETAILS			
FILTER MEDIA	FILTER CAPACITY	FILTER DIMENSION	MOC
HDPE + Non-Woven Synthetic Media + HDPE Supported By Al Rod	1000 CFM	610 X 305 X 305 MM	ALUMINIUM
AIR FLOW RATE	INITIAL PRESSURE DROP	FINAL PRESSURE DROP	TEMPERATURE
1000 CFM	70 - 80 Pa	450 Pa	AMBIENT
TEST DATA			
TEST AIRFLOW	AIR VELOCITY	AIR TEMPERATURE	
1000 CFM	500 FPM	25 °C	
TEST RESULT			
INITIAL PRESSURE DROP (Pa)	EFFICIENCY	FILTER CLASS	
70 ± 5 %	99% DOWN TO 03 MICRON	EU 07	
TEST TYPE : BS EN 779			



INSPECTED BY



Authorised Signatory

For Queries Related To TC Please Contact : quality@airfil.in