

ELECTRICAL SYMBOLS

-MOUNT 12" A.F.F. UNLESS OTHERWISE NOTED

-MOUNT 18" A.F.F. UNLESS OTHERWISE NOTED VOLTAGE AND AMPACITY AS PER PLANS

-MOUNT 44" A.F.F. UNLESS OTHERWISE NOTED
3= 3=THREE-WAY M = 20 A, MOTOR RATED
4 = 4- WAY D= 1.2 KW DIMMER
OS = PROVIDE OCCUPANCY SENSOR

- PHOTOELECTRIC SMOKE DETECTOR (110 V. WITH BATTERY BACK-UP, INTERCONNECTED WITH RESIDENCE SMOKE

-PHOTOELECTRIC SMOKE DETECTOR & CARBON MONOXIDE DETECTOR COMBINATION (120V) W/BATTERY BACK UP

60 - SWITCH SIZE, *

-SIZED AND FUSED AS PER EQUIPMENT

DETECTION SYSTEM AND SOUNDING BASE)

-VERIFY MOUNTING HEIGHT

-VERIFY EXACT LOCATION

NAME PLATE RATING

-DUPLEX RECEPTACLE

-EQUIPMENT RECEPTACLE

-G.F.I. RECEPTACLE

15 AMP/120 VOLT

-SMOKE DETECTOR

-CO / SMOKE DETECTOR

-TELEVISION OUTLET

-DISCONNECT


15 AMP/120 VOLT (TAMPER RESISTANT)

15 AMP/120 VOLT (TAMPER RESISTANT)

ELECTRICAL LIGHTING FLOOR PLAN
SCALE: 1/4" = 1'-0"

13418 SW 128th ST. SUITE A. MIAMI FL, 33186 TEL:(305) 505 2219 FAX: (786) 558-4528 E-mail: martdesign@bellsouth.com.

IARTIENEZ & ASSOCIATES MEP DESIGN.CO, EREBY RESERVES ITS LAW COPYRIGHTS AND OTHER PROPERTY RIGHTS IN THESE PLANS, IDEAS, AND DESIGN. THESE PLANS, IDEAS, AND DESIGNS ARE NOT TO BE REPRODUCED, CHANGED OR COPIED IN ANY FORM OR MATTER TO ANY THIRD PARTY WITHOUT FIRST OBTAINING THE EXPRESS WRITTEN PERMISSION, CONSENT, AND APPROPRIATE COMPENSATION TO MARTINE & ASSOCIATES MEP DESIGN CO. VER SCALE DIMENSIONS, CONTRACTOR SHALL AND CONDITIONS OF THE JOB AND MARTINEZ & SOCIATES MEP DESIGN CO. TO BE NOTIFIED IN MENSIONS CONDITIONS AND SPECIFICATI



SHEET TITLE:

LIGHTING FLOOR PLAN SYMBOLS **GENERAL NOTES**

t Number | 021123A

2 OF 3