

Remarks: **PLUMBING** - C2023085319

Code	Description	Created	Modified
REMARK	ENTERED 04/06/2023 RJL 04-06-2023 ROBERT JONES GOLD KEY 786-315-2030. RJL@MIAMIDADE.GOV :THIS REVIEW IS FOR ALT/EXT/INT 1.PLEASE SHOW WATER SERVICE FROM WELL/METER TO STRUCTURE ON SITE PLAN.(SHEET A-101) PLEASE PROVIDE SEWER LINE FROM SEPTIC TANK OR PUBLIC SEWER TO STRUCTURE ON SITE PLAN.FBC 107.3.5 2.SHOW DIMENSIONS OF BATHS TO COMPLY WITH MINIMUM FIXTURE CLEARANCE REQUIREMENTS OF FBC P2705.1(5) P2708.1.1 P2708.1(LAVS SHOWER ETC PG A102)	JONES, ROBERT 04/06/2023	

Showing 1 to 1 of 1 entries