

Remarks: **DERM FLOOD** - C2023085319

Code	Description	Created	Modified
REMARK	This project results in a substantial improvement and therefore must comply with all required elevations.	ESTEVEZ, CARLOS M. 04/06/2023 9:54 AM	ESTEVEZ, CARLOS M. 04/06/2023 9:55 AM
REMARK	For code (254) proposed Lowest Adjacent Grade (8.8' ngvd) does not comply with minimum requirement of 9.02' ngvd. (Lowest Adjacent Grade cannot be below County Flood Criteria of 9.02' ngvd)	ESTEVEZ, CARLOS M. 04/06/2023 9:53 AM	ESTEVEZ, CARLOS M. 04/06/2023 9:55 AM
REMARK	For code (260) provide Top of A/C Slab Elevation on Site Plan.	ESTEVEZ, CARLOS M. 04/06/2023 9:51 AM	ESTEVEZ, CARLOS M. 04/06/2023 9:55 AM
REMARK	Please note that additional comments may follow pending information to be provided.	ESTEVEZ, CARLOS M. 04/06/2023 9:51 AM	ESTEVEZ, CARLOS M. 04/06/2023 9:55 AM
0254	Adjacent grade not in compliance with Chapter 11C -3(m).	ESTEVEZ, CARLOS M. 04/06/2023 9:47 AM	ESTEVEZ, CARLOS M. 04/06/2023 9:55 AM
0260	All Electrical / Plumbing / Mechanical equipment shall be above required elevation as per Chapter 11C-5(f)(4).	ESTEVEZ, CARLOS M. 04/06/2023 9:47 AM	ESTEVEZ, CARLOS M. 04/06/2023 9:55 AM

Showing 1 to 6 of 6 entries

