

Remarks: **STRUCTURAL** - C2023085319

Code	Description	Created	Modified
REMARK	<div>ENTERED 04/10/2023 JOO</div> <div>1. PROVIDE SPECIAL INSPECTOR FORM FOR SOIL COMPACTION AND REINF MASONRY - CMDC 8-22.</div> <div>2. SEE NOTE 10 IN S-1.0 - PROVIDE DETAIL FROM FOUNDATIN TO EXISTING BEEAM. PROVIDE DOWEL CONNECTION DETAIL BETWEEN EXISTING TB AND NEW BEAMS WITH ELEVETIONS.</div> <div>3. IN 1/S-3.0, SHOW/PROVIDE ROOF SHEATHING AT MAIN ROOF TRUSS AND SPECIFY CONNECTOR BETWEEN PIGGYBACK TRUSS TO MAIN TRUSS. SPECIFY OPEN CEILING - UNDER TRUSS AT TERRACE AREA ( RB-1) SIDE FOR WINDS NOT TO PENETRATE INTO BLDG.</div>	<div>JOO, YUN SOOL</div> <div>04/10/2023</div>	

Showing 1 to 1 of 1 entries

