

Maintenance Form - Section 2.45.1

General Information

Section: 2.45.1

Equipment/System: Audible & Visual Escape

Inspector: Aaaaaaaa

Date: 2026-02-19

Drawing Reference:

Locations: EASTBOUND BORE, COUNTY HALL, SUMP PUMPING STATION

Frequencies: MONTHLY, 3 MONTHLY, 6 MONTHLY, ANNUALLY

Tasks Performed

☒ Carry out visual inspection of chaser lighting at each Emergency door position and check for damage.

Carry out repair / replacement to damaged units as necessary.

☒ Manually operate the system at each door position. Ensure that:

Each arrow functions and is sequential.

Strobe lighting on sign operates and sign is illuminated.

Audible sound and white noise alert are operational

☐ Replace any defective components necessary to bring the system back into full service.

☐ Inspect control panel for signs of water ingress and security of all connections and components.

☐ Operate door from EPCMS and log door checked.

Photos



Approval

Engineer: AAAAA (A)

Date: 2026-02-19

Supervisor: AAAAAAS (A)

Date: 2026-02-19

Generated: 19/02/2026 23:28:27