

Maintenance Form - Section 2.45.3

General Information

Section: 2.45.3

Equipment/System: Audible & Visual Escape

Inspector: A

Date: 2026-02-19

Drawing Reference:

Locations: WESTBOUND BORE, COUNTY HALL, SUMP PUMPING STATION

Frequencies: 6 WEEKLY, 3 MONTHLY, 6 MONTHLY, ANNUALLY

Tasks Performed

- ☒ Carry out visual inspection of chaser lighting at each Emergency door position and check for damage. Carry out repair / replacement to damaged units as ne
- ☒ Manually operate the system at each door position. Ensure that: Each arrow functions and is sequential. Strobe lighting on sign operates and sign is illumina
- ☐ Replace any defective components necessary to bring the system back into full service.
- ☐ Inspect control panel for signs of water ingress and security of all connections and components.
- ☐ Operate door from EPCMS and log door checked.

Photos



Approval

Engineer: Simon Morgan (SM)

Date: 2026-02-19

Supervisor: Francisco Roldan (FR)

Date: 2026-02-19

Generated: 19/02/2026 23:10:18