



Maintenance Form - Section 2.8.3

General Information

Section: 2.8.3

Equipment/System: FIREFIGHTING WATER

Inspector: Number 1

Date: 2026-03-04

Drawing Reference: B13/1 - 13/6

Locations: EASTBOUND BORE, COUNTY HALL

Frequencies: 6 MONTHLY

Tasks Performed

- ☒ Check operation of hydrant by flushing through the unit
- ☒ Check that hydrant blanks are attached to the hydrant
- ☐ Check hand wheels are not damaged. Replace if necessary
- ☐ Check that all quick release assemblies are working
- ☐ Remove blank plug and check that Inst. washer inside outlet is damaged or perished.
Replace if necessary. Replace blank plug.
- ☐ Check hydrant and pipework for leaks. If leaks tighten the appropriate bolts or spindle securing nut. If required change spindle packing.

Maintenance Engineer Comments

Number 1

Approval

Engineer: Number 1 (N1)

Date: 2026-03-04

Supervisor:

Date: 2026-03-04

Council:

Date: 2026-03-04

Generated: 04/03/2026 17:47:39