



## Maintenance Form - Section 2.45.1

### General Information

**Section:** 2.45.1

**Equipment/System:** Audible & Visual Escape

**Inspector:** Matchtech

**Date:** 2026-03-04

**Drawing Reference:**

**Locations:** EASTBOUND BORE, COUNTY HALL, SUMP PUMPING STATION

**Frequencies:** 6 MONTHLY

### Tasks Performed

☒ Carry out visual inspection of chaser lighting at each Emergency door position and check for damage.

Carry out repair / replacement to damaged units as necessary.

☒ Manually operate the system at each door position. Ensure that:

Each arrow functions and is sequential.

Strobe lighting on sign operates and sign is illuminated.

Audible sound and white noise alert are operational

☐ Replace any defective components necessary to bring the system back into full service.

☐ Inspect control panel for signs of water ingress and security of all connections and components.

☐ Operate door from EPCMS and log door checked.

Maintenance Engineer Comments

Matchech

Council Approval Comments

Cardiff Council

Approval

Engineer: Matchtec (M)

Date: 2026-03-04

Supervisor:

Date: 2026-03-04

Council: Card (C)

Date: 2026-03-04

Generated: 04/03/2026 17:44:07