



Maintenance Form - Section 2.45.3

General Information

Section: 2.45.3

Equipment/System: Audible & Visual Escape

Inspector: Matchtech

Date: 2026-03-04

Drawing Reference:

Locations: WESTBOUND BORE, COUNTY HALL, SUMP PUMPING STATION

Frequencies: 6 MONTHLY

Tasks Performed

- ☐ Carry out visual inspection of chaser lighting at each Emergency door position and check for damage.
Carry out repair / replacement to damaged units as necessary.
- ☐ Manually operate the system at each door position. Ensure that:
Each arrow functions and is sequential.
Strobe lighting on sign operates and sign is illuminated.
Audible sound and white noise alert are operational
- ☒ Replace any defective components necessary to bring the system back into full service.
- ☒ Inspect control panel for signs of water ingress and security of all connections and components.
- ☒ Operate door from EPCMS and log door checked.

Maintenance Engineer Comments

mmATCHTECH

Approval

Engineer: Match (M)

Date: 2026-03-04

Supervisor:

Date: 2026-03-04

Council:

Date: 2026-03-04

Generated: 04/03/2026 17:43:11