



Maintenance Form - Section 2.36.8

General Information

Section: 2.36.8

Equipment/System: CONTROL/COMM CABLES

Inspector: A

Date: 2026-02-22

Drawing Reference:

Locations: FIRE PUMPING STATION

Frequencies: ANNUALLY, 3 YEARLY

Tasks Performed

- ☐ Visually inspect all accessible control/comms cables for any signs of damage, defects, or corrosion etc. Rectify / Repair where necessary
- ☐ Ensure Electrical Segregation is maintained
- ☒ Ensure all cables are dressed neatly and clearly identified
- ☐ Check the security of all terminations
- ☐ Check with CCC Engineer for any known defects on the communications / control network and rectify where necessary

Approval

Engineer: D (D)

Date: 2026-02-22

Supervisor: a (a)

Date: 2026-02-22

Generated: 22/02/2026 13:22:18