

Maintenance Form - Section 2.38.3

General Information

Section: 2.38.3

Equipment/System: Door Dampers control room (2 units)

Inspector: D

Date: 2026-02-22

Drawing Reference: B1/39

Locations: SERVICE BUILDING, SUMP PUMPING STATION

Frequencies: 6 MONTHLY, ANNUALLY

Tasks Performed

- ☒ Isolate Damper unit
- ☐ Clean all Grilles associated with each damper and check for damage
- ☐ Check the security of the damper blades and grilles
- ☐ Check for the correct operation
- ☐ Check alignment of damper blades
- ☐ Check all electrical connections for security and signs of burning
- ☐ Leave unit in full service and report any defects to the Duty Engineer

Approval

Engineer: D (D)
Date: 2026-02-22

Supervisor: D (D)
Date: 2026-02-22